

TYPICAL OVERHEAD PERMANENT SERVICE

- An inspection by a Municipality approved inspector is required (per UCC code).
- ALL EQUIPMENT SHOWN (except the service drop and its attachment) WILL BE PROVIDED AND INSTALLED BY THE MEMBER.
- Cooperative service drop max. length - 150' from nearest pole (250' from transformer).

